

# WSPCert Certificate

**No. BAC-0173-01**

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5:2012. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed in the annex of this certificate.

The BACnet Smart Sensor (B-SS)

**EE160, EE210**

with the software version:

**1.8**

of

**E+E Elektronik Ges.m.b.H.**

Langwiesen 7, 4209 Engerwitzdorf, Austria

has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 12.0 and the Certification Rules of the BACnet Interest Group Europe, see **MBS Test Report No. VG 2014\_9451.**

The certificate is valid  
until 2016/04/01

2015/03/02

Date of initial certification



Dipl.-Ing. G. Weinmann  
Head of Certification Body

Empowered by



## Annex to Certificate No. BAC-0173-01

The certification of the BACnet Implementations

**EE160, EE210**

of **E+E Elektronik Ges.m.b.H.**

refers to the BACnet Interoperability Building Blocks (BIBBs) listed below. BIBBs other than listed are not part of the certification.

BACnet Interoperability Building Blocks	
DS-RP-B	Data Sharing – Read Property – B
DS-RPM-B	Data Sharing – Read Property Multiple – B
DS-WP-B	Data Sharing – Write Property – B
DM-DDB-B	Device Management – Dynamic Device Binding – B
DM-DOB-B	Device Management – Dynamic Object Binding – B
DM-DCC-B	Device Management – Device Communication Control – B
DM-RD-B	Device Management – Reinitialize Device – B